

UNCLASSIFIED

AD NUMBER
AD424552
NEW LIMITATION CHANGE
TO Approved for public release, distribution unlimited
FROM Distribution authorized to U.S. Gov't. agencies and their contractors; Administrative/Operational Use; 11 Nov 1963. Other requests shall be referred to United States Naval Civil Engineering Lab., Port Hueneme, CA.
AUTHORITY
USNCBC ltr, 24 Oct 1974

THIS PAGE IS UNCLASSIFIED

**UNCLASSIFIED**

**AD 4 2 4 5 5 2**

**DEFENSE DOCUMENTATION CENTER**

**FOR**

**SCIENTIFIC AND TECHNICAL INFORMATION**

**CAMERON STATION, ALEXANDRIA, VIRGINIA**



**UNCLASSIFIED**

NOTICE: When government or other drawings, specifications or other data are used for any purpose other than in connection with a definitely related government procurement operation, the U. S. Government thereby incurs no responsibility, nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use or sell any patented invention that may in any way be related thereto.

AD No. 424552  
DDC FILE COPY

621000

NCEL R263

1

R 263 ✓

Technical Report

TEST OF GERMAN SAND-TYPE FILTER,

11 November 1963,

DEC 14 1963



U. S. NAVAL CIVIL ENGINEERING LABORATORY

Port Hueneme, California

NO OTS

J.C.

# TEST OF GERMAN SAND-TYPE FILTER

16 Proj. Y-F011-05-338b

Type C (9) Final Report,

(10) by

J. M. Stephenson.

## ABSTRACT

*Presented is a sand filter*

The shelter equipment developed by the Artos Machinery Company of Germany specifies a sand filter which the U. S. Naval Civil Engineering Laboratory evaluated with respect to ventilation characteristics and effectiveness in protecting a shelter from the hot blast of a nuclear explosion. Tests indicated an airflow of 4 cfm per square foot of filter area for a 36-inch depth of sand, 6 cfm for a 24-inch depth, and 12 cfm for a 12-inch depth when the pressure drop is 1-inch water-gaged. Special equipment was built to release compressed air to simulate the blast from a nuclear explosion. A model shelter consisting of a steel tank was connected to the air-blast device through an 8-inch-diameter sand filter. The filter proved to be reasonably effective in attenuating blast when subjected to overpressures up to 100 psi with a positive time duration of about 2 seconds. However, the effectiveness varied with changes in the size of sand grains even though the changes were within the filter specifications.

The heat-absorbing characteristics of the sand were studied under conditions similar to a nuclear blast, by subjecting the filter to blasts of hot pressurized air. Heat-absorption characteristics were also studied, in 24-hour tests simulating night and day, when ventilating air of varying temperatures was passed through the filter. The sand proved to be an excellent heat absorber, maintaining the outlet temperature at an acceptable level.

Since a sand filter is not a positive closure device, it has a typical response for a given impulse and the response depends on its physical characteristics. Consequently, if a filter is to be classified as safe for a certain overpressure and time duration, the filter as a unit should be pretested or the sand must be very carefully graded and matched against control samples.

Qualified requesters may obtain copies of this report from DDC.  
The Laboratory invites comment on this report, particularly on the results obtained by those who have applied the information

## INTRODUCTION

Following World War II the use of sand filters for shelter-ventilation systems was investigated and to some extent adopted in Germany and other parts of Europe. Consequently, information on the size of sand grains, on the depth of sand, and on various other characteristics was available but the capacity of the sand to protect against blast and heat was uncertain. NCEL was assigned a task to obtain more extensive data on the normal ventilation characteristics and to determine if sand could protect the shelter from the hot blasts of nuclear explosions and heated ventilating air resulting from fires. This information was obtained by three separate experiments; the first deals with ventilation characteristics under normal operating conditions, the second with blast attenuation, and the third with heat absorption. This work was partially sponsored by the Defense Atomic Support Agency through the Bureau of Yards and Docks.

## VENTILATION FLOW CHARACTERISTICS

### Description of Equipment

Figure 1 shows the method used to determine airflow rates and pressure drops through the sand filter. Because they are more accurate, compressed air and rotameters were used in preference to a pressure fan and pitot tube. The box holding the sand was 1 square foot in cross section and was deep enough to test 40 inches of sand. The sand was supported by a perforated steel plate, a screen, and 2 inches of gravel.

The sand used in this test conformed to the Artos Machinery Company specifications: 80 to 90 percent from 1 mm to 3 mm, 5 to 15 percent from 0.2 mm to 1 mm, and up to 5 percent less than 0.2 mm.

### Test Procedure

A layer of 12 inches of sand was placed on the gravel support and vibrated with a concrete vibrator. Compressed air was then allowed to flow through the sand, and the airflow rate was measured by the rotameter and the static pressure drop by a micrometer. This procedure was repeated for 24 and 36 inches of sand, with 6 to 10 readings for each depth.

66




Figure 1. Determination of airflow rate through sand.

## Test Results

The data from these tests is shown in Table I. At a 1-inch static pressure drop (probably the limit for hand-operated equipment) the flow is almost inversely proportional to the depth. Table II shows the filter cross-section areas which would be required for various shelter populations based on a ventilation rate of 3 cfm per person and a 1-inch static pressure drop. Table II emphasizes the large areas required for 100 people, particularly when a 36-inch depth of sand is necessary.

Table I. Static Airflow Rates Through Sand (in cfm per sq ft of filter area)

Sand Depth (in.)	Pressure Drop (in. of water)						
	0.2	0.4	0.6	0.8	1.0	1.2	1.4
12	2.7	5	7.2	9.5	12	14	16
24	1.3	2.3	3.6	4.8	6	7	8
36	1	1.8	2.5	3.3	4	4.8	5.6

Table II. Filter Cross-Section Area Required for Ventilation (at 3 cfm per person and 1 in. W. G. static pressure drop)

Sand Depth (in.)	No. of People in Shelter			
	25	50	75	100
12	6.25 ft <sup>2</sup>	12.5 ft <sup>2</sup>	18.75 ft <sup>2</sup>	25 ft <sup>2</sup>
24	12.5	25	37.5	50
36	18.75	37.5	56.2	75



## BLAST ATTENUATION

If a sand filter were built into the ventilation system of a shelter and tested in the field with a nuclear bomb, the shock wave emanating from the bomb and traveling somewhat faster than the speed of sound would approach the filter like a wall of compressed air. As the wave front approached, the overpressure would rise very rapidly to a maximum. As the wave front passed, the pressure would taper off to zero and become negative. The filter would therefore be subjected to a sudden peak overpressure followed by diminishing pressure. The magnitude and duration of the overpressure depends on the size of the bomb and the distance from ground zero to the point of measurement. The positive phase of a nuclear blast can be simulated on a small scale by using compressed air. A model (Figure 2) was built in which a large steel tank, called an Air Blast Device, held the compressed air, and another steel tank, called the plenum chamber, represented a shelter. A sand filter connected to this plenum chamber was subjected to various overpressures.

Rather than a true model it was necessary to design an adequate model in which the depth of the filter and characteristics of the sand were the same as the prototype. The cross-sectional area of the filter and volume of the plenum were reduced in scale by equal amounts. All of the quantities pertaining to the dynamic load, including the rise time and overpressure, were scaled the same in the model as in the prototype. Factors and pi terms for the dimensional analysis are shown in Table III. There are an infinite number of shelter-to-filter combinations; Table IV shows those tested in this experiment. The ventilation rates are based on a 1-inch water pressure drop.

Table III. Dimensional Analysis

Factors		Pi Terms		
u	velocity of air			
q	overpressure applied to filter	$\frac{q}{\rho u^2}$	$\frac{v_1}{v_2}$	$\frac{p}{q}$
p	pressure rise in plenum			
$\mu$	viscosity			
a	area of filter	$\frac{\rho u v_1}{\mu a}$		$\frac{u}{g \tau}$
$v_1$	volume of filter			
$v_2$	volume of plenum			
$\tau$	time	$\frac{u^2 a}{g v_1}$		$\frac{\rho u^2 \tau}{\mu}$
g	acceleration of gravity			
$\rho$	density of air			




Figure 2. Model and Air Blast Device.

Table IV. Shelter-to-Filter Combinations

Filter Depth (in.)	Shelter Volume Filter Area (cu ft/sq ft)	3 cfm per Person		5 cfm per Person	
		Space per Person (cu ft)	Filter Area per Person (sq ft)	Space per Person (cu ft)	Filter Area per Person (sq ft)
12	88 <sup>1/</sup>	22	0.25	38	0.417
24		44	0.50	76	0.834
36		66	0.75	114	1.250
12	132 <sup>2/</sup>	33	0.25	56	0.417
24		66	0.50	112	0.834
36		99	0.75	168	1.250
12	176 <sup>3/</sup>	44	0.25	75	0.417
24		88	0.50	150	0.834
36		132	0.75	225	1.250

<sup>1/</sup> Based on 8-inch-diameter filter and 30-cubic-foot plenum.

<sup>2/</sup> Based on 8-inch-diameter filter and 45-cubic-foot plenum.

<sup>3/</sup> Based on 8-inch-diameter filter and 60-cubic-foot plenum.

### Description of Air-Blast Device

Figure 3 shows a diagram of the fundamental components. The volume of compressed air is controlled by partially filling the tank with water. When the air-actuated plug valve is opened, air rushes into the tube and builds up a pressure on the mylar diaphragm. The diaphragm bursts, resulting in a sudden pressure-rise on top of the sand and a restricted airflow into the plenum. When the air-actuated plug valve opens, two relief valves also open, causing the pressure on the sand to drop quite rapidly. As a result of this sequence of operation, the pressure immediately above the sand reaches a peak in 20 to 45 milliseconds and then decays to almost zero within one to six seconds. Preliminary tests in the NCEL Atomic Blast Simulator in which the rise time was 4 milliseconds resulted in a gradual pressure rise below the sand, indicating flow phenomena; consequently the rise times of 20 to 45 milliseconds were considered satisfactory. The peak pressure obtained with the Air Blast Device is a function of the original pressure in the supply tank. Decay time is controlled by presetting the water level in the supply tank to adjust the volume of air and by partially opening the two gate valves to govern the rate of airflow from the tank. In an actual blast, the overpressure at any time can be closely represented by the empirical equation <sup>1</sup>

$$p(t) = p \left( 1 - \frac{t}{t+} \right) e^{-t/t+}$$

where  $p(t)$  is the overpressure at any time,  $t$ , after the arrival of the shock front;  $p$  is the peak overpressure; and  $t+$  is the duration of the positive phase of the blast wave. The pressure process represented by this equation may be approximated rather well by the equipment just described.

Pressure cells (strain gages) were installed in the plenum and a few inches above the sand filter. Rapid-response thermocouples were installed above and below the sand and in the plenum. Leads from both pressure cells and thermocouples were connected through amplifiers to a Consolidated Electrodynamic Corporation oscillograph which records on light-sensitive paper. A typical set of traces copied directly from an oscillograph record is shown in Figure 4; since the traces are made by tiny rays of light which produce solid lines on the paper, their positions must be separated at the origin in order to identify them.




Figure 3. Diagram of model and Air Blast Device.




Figure 4. Traces copied from oscillograph record.

## Test Procedure

The tests on the blast attenuation of the filter were done in three sections: A, B, and C. Section A was an extensive test of an 8-inch diameter filter. The size of the sand grains conformed to the Artos specifications. Section B, although similar to A, was less extensive and used a 12-inch diameter filter. Section C was a test of the 8-inch diameter filter, but the sand gradations were carefully controlled. In all tests, the sand was kept dry and was compacted by tapping the outside of the filter with a hammer. The following information was collected:

$p_s$  — pressure in supply tank before shot

$p_a$  — pressure immediately above sand

$p_p$  — pressure in plenum

$t_a$  — temperature immediately above sand

$t_b$  — temperature immediately below sand

$t_p$  — temperature in plenum

Section A Tests. The sand used in the Section A tests was taken at random from a batch graded as follows: 80 to 90 percent from 1 mm to 3 mm; 5 to 15 percent from 2 mm to 1 mm; and 0 to 5 percent less than 2 mm.

The Section A tests conducted are tabulated as follows:

Plenum Volume (ft <sup>3</sup> )	Filter Diameter (in.)	Filter Depth* (in.)	Overpressure** (psi)	Time Duration (sec)
30, 45, 60	8	12, 24, 36	15, 30, 45 60, 75, 100	2

\* These depths were used with each plenum volume.

\*\* These values of overpressure were applied to each filter depth.

Section B Tests. The sand prepared for the Section A tests was also used in the Section B tests of a 12-inch-diameter filter.

The Section B tests are tabulated as follows:

Plenum Volume (ft <sup>3</sup> )	Filter Diameter (in.)	Filter Depth* (in.)	Overpressure** (psi)	Time Duration (sec)
105	12	24, 36	15, 30, 45 60, 75, 100	2

\* Each filter depth tested with the one plenum volume.

\*\* These values of overpressure were applied to each filter depth.

Section C Tests. The Artos Machinery Company specified that 80 to 90 percent of the sand should be between 1 to 3 mm; up to 15 percent between 0.2 and 1 mm; and 0 to 5 percent less than 0.2 mm. Without a normal distribution, one sample of sand might have a preponderance of particles close to 3 mm, and another sample might be largely 1 mm plus the maximum percentage of finer particles. To study the effect of such abnormal particle distributions, the following two samples were tested:

Sample	U. S. Sieve No.	Particle Size (mm)	Percentage
1 (coarse)*	6-8	2.38 - 3.36	100
2 (fine)**	12-16	1.19 - 1.68	90
	50-60	.25 - .30	5
	60 and smaller	.25 and less	5

\* See Figure 5

\*\* See Figure 6






Figure 5. Sample of coarse sand.




Figure 6. Sample of fine sand.

The Section C tests on each of the samples above are tabulated as follows:

Plenum Volume (ft <sup>3</sup> )	Filter Diameter (in.)	Filter Depth* (in.)	Overpressure** (psi)	Time Duration (sec)
30, 45	8	36	80, 100	2

\* This depth tested with each plenum volume.

\*\* Both values were applied to filter.

It should be noted that in Section A, B, and C tests, the overpressures and time durations could not be controlled accurately so the values shown are only approximate.

#### Test Results

Figures A-1 through A-4 in Appendix A, show the curves of plenum pressure versus overpressure for the Section A tests. Figure A-5 shows the curves of Section B tests, and Figures A-6 and A-7 show curves of the Section C tests.

It was assumed that the most useful way to present the data would be to plot plenum pressure versus overpressure. This could not be done directly because the duration of the shock would have to be the same for all shots, and it was not practical to obtain uniform time durations. However, impulse combines the time with overpressure and values for impulse were plotted against plenum pressure. It was then easy to work backwards and obtain the values to plot plenum pressure versus overpressure at the prescribed time duration of 2 seconds. An example showing how this correction procedure was done is given in Appendix B. Table B-1 in Appendix B is a typical set of data, and Figure B-1 is a graph showing plenum pressure versus impulse. The resulting plenum pressure versus overpressure for this set of data is shown in Figure A-3.

The Section B tests were made to determine whether a larger size filter connected to a larger plenum would show any unexpected results which could be attributed to effects from the wall of the filter or to other flow phenomena. The 49-square-inch filter area and 45-cubic-foot plenum volume used in the Section A tests were a little more than doubled for this experiment, but the results revealed nothing unusual. In Figure A-5, there are small and inconsistent differences in plenum pressure as compared with the Section A tests, but these differences are probably due to sand distribution as determined in the Section C tests.

The results of the Section C tests show that the airflow through the sand varied considerably as the size distribution of the grains was changed, even though the distribution remained within the specifications of the Artos Machinery Company. The fine sand and the specified sand both meet specifications. The coarse sand contains 100 percent of the largest grains, but, even so, it comes close to meeting the specifications.

Figure A-6 emphasizes how the samples differed from each other in resisting the blast. At 100 psi overpressure (2 seconds duration), the fine sand permitted a pressure rise of only 3 psi in the plenum. On the other hand, the coarse sand permitted a pressure rise of over 9 psi in the plenum. It is evident that a modest change in particle size causes a marked change in the blast-attenuating properties of the sand. In view of the fact that sand has a natural tendency to segregate and in view of the fact that 90 percent of the Artos sand can be as large as 3 mm or as small as 1 mm, it is not surprising that every batch has its own characteristics. Consequently, if a sand filter is to be used in higher overpressure regions, e.g., 100 psi at 2 seconds duration, the sand must be carefully graded. If a sand filter is to be used in low overpressure regions, e.g., 25 psi at 2 seconds duration, the Artos sand or similar commercial grades would be satisfactory. The time duration is of course extremely important when considering the sand as a blast attenuator. Since the sand is not a closure device, it can only retard the airflow, it cannot exclude it. The cost of carefully graded sand is approximately six times greater than Artos-type sand. As for other sands, such as those from beaches or dry river beds, it would seem to be a dangerous practice to use them. Probably the only safe approach to the whole problem would be to pretest the filter as a unit or to carefully grade the sand and match it against control samples.

The tests in this task have been very useful in giving an evaluation of the Artos Sand Filter. The results of the specified sand indicate that under minimum conditions\* of ventilation and occupancy the filter would give blast protection\*\* from a 1-megaton burst, to a shelter located 3500 feet or more from ground zero. In this instance the overpressure would be 100 psi and the time duration 1.4 seconds. It would probably give protection from a 10-megaton burst, to a shelter located 10,000 feet from ground zero, in which case the overpressure would be 50 psi and the time duration 2.8 seconds.

---

\* 3 cfm fresh air per person and 66 cubic feet of space per person

\*\* Blast protection here assumes a 5-psi maximum-allowable pressure rise in the shelter<sup>2</sup>

## CHARACTERISTICS OF SAND FILTERS WITH RESPECT TO ABSORPTION AND DISSIPATION OF HEAT

### Hot-Blast Tests

If a shelter with a sand filter were tested in the field with a nuclear blast of 100 psi, the temperature of the air striking the filter would be about 730 F\* at the time of maximum pressure. The air would then expand isentropically causing the temperature to drop to about 200 F by the end of the positive phase of the blast.

The temperatures recorded at peak overpressures in the blast-attenuation tests were lower than the theoretical values so a series of tests was made using preheated pressurized air. Figure 7 shows the equipment, including a 3.7-cubic-foot tank which was mounted horizontally and connected to the top of the 8-inch shock tube. Inside the tank, four heaters controlled by a variable transformer heated the air. The location of thermocouples and pressure cells is shown in Figure 7. The filter was 36 inches deep and the plenum volume was 45 cubic feet.

Four shots using heated air were made at 15-minute intervals in order to study the movement of the temperature gradient through the sand. The results are shown in Table V. All shots indicated good simulation of the pressure decay curve. Although the temperature of the air dropped sharply as it expanded from the hot tank, it dropped at a slow rate after striking the sand. Consequently, the tests were reasonably severe. After the four shots, the temperature measured at 2 inches below the sand surface had risen from ambient to 260 F, but at 6 inches below the surface the maximum temperature recorded was only 83 F. During this same period, the temperature 24 inches below the surface had actually dropped from 63 F to 61 F. The thermodynamic processes in the sand filter are probably as follows: the first few inches of sand quickly absorbs heat from the high-temperature air, and, as it passes through the sand, the air cools still further from expansion. However, the sand prevents the air from cooling more by adding heat when the temperature of the air is lower than that of the sand. The process is, therefore, not adiabatic but one in which the sand moderates the air temperature because of its relatively large heat-storage capacity. Thus, it seems doubtful if a blast of 100 psi overpressure at 730 F would offer any temperature hazards to the occupants of a shelter protected with a 36-inch sand filter.

---

\* Temperature calculated from Hugoniot equation




Figure 7. Hot-blast equipment.

Table V. Hot-Blast Shots

	Shot 1	Shot 2	Shot 3	Shot 4
Temperature in hot air supply tank	661 F	655 F	670 F	668 F
Peak overpressure on sand	68.8 psi	83.2 psi	77.6 psi	77.2 psi
Duration of shot	2.2 sec	1.85 sec	1.85 sec	1.85 sec
Thermocouple temperature				
A — above sand				
before shot	75 F	88 F	88 F	90 F
maximum	360 <sup>1/</sup>	363 <sup>1/</sup>	368 <sup>1/</sup>	369 <sup>1/</sup>
end of shot	258	250	275	275
1 — 2 in. below sand surface				
before shot	69	162	208	238
end of shot	93	206	232	260
2 — 6 in. below sand surface				
before shot	65	67	69	75
end of shot	65	68	72	83
3 — 12 in. below sand surface				
before shot	60	61	62	63
end of shot	60	61	62	64
4 — 24 in. below sand surface				
before shot	63	63	62	61
end of shot	62	62	61	61
B — air below sand				
before shot	61.5	61	60	59
end of shot	60	58.5	57	56.5
P — air inside plenum				
before shot	67.5	71.5	71	72
end of shot	88	86	80.5	78
Pressure rise in plenum	3.8 psi	4.4 psi	4.1 psi	3.9 psi

<sup>1/</sup> A temperature of 360 F is associated with a shock-wave overpressure of approximately 40 psi.

## Controlled Temperature Ventilation Tests

When hot air is drawn through a buried sand filter, it may be assumed in advance that the sand will act as a moderator to prevent the ventilating air from entering the shelter at a high temperature. Its effectiveness in this respect depends on its ability to absorb heat from the air, and then reject it to the surrounding soil or to subsequent cool air. Some soils have a high resistance to heat flow, in which case the absorbed heat would be retained by the sand until slowly carried into the shelter by the cooler air. Conversely, some soils have a low resistance to heat flow, in which case the absorbed heat would be readily transferred to the soil enhancing the action of the sand as a moderator. Figure 8 illustrates the equipment with which warm air was passed through the filter.

The filter was wrapped with 1 inch of fiberglass insulation. Four tests were run at different airflows and inlet temperatures. Complete data can be seen by examining Table VI and Figures 9, 10, 11, and 12. The significance of 1.3 cfm and 3.5 cfm is their relationship to static pressure drop across 3 feet of sand. The lower value corresponds to approximately 1 inch of water and the higher value to 2.5 inches of water. The entering air temperatures in Tests 1, 3, and 4 are presumably more rigorous than any situation which would be encountered in an actual situation. Calculations were made to determine how much heat the filter could reject to the soil. Two soils were considered: soil A, having a thermal conductivity of 0.22 Btu/hr/sq ft/(deg F/ft) and thermal diffusivity of 0.011 sq ft/hr; and soil B, having a thermal conductivity of 0.80 and thermal diffusivity of 0.024. Ingersoll's<sup>3</sup> formula was used in the calculations, assuming that the soil had been absorbing heat from normal ventilation for two weeks. Other pertinent factors are given in Table VI.

The results of the four tests have been summarized in Table VI and Figures 9, 10, 11, and 12. In all cases the ability of the sand to absorb heat was excellent. It can be seen from item 12 in Table VI that soil A would be unable to absorb the total heat dissipated to the atmosphere. Item 13 indicates that soil B could absorb much more than the total heat dissipated.

If the sand filter for an actual shelter consisted of a large concrete container (Figure 13) much of the heat absorbed by the sand would be trapped in the center of the filter and carried into the shelter before it could be dissipated to the soil. Therefore, if it is the engineer's intention that the filter reject as much heat as possible to the soil, it would be necessary to use a pipe grid (Figure 14) or possibly a long narrow concrete container with a large amount of the surface exposed to the soil. The practice of drawing in heated air for shelter ventilation is questionable since this air may contain carbon monoxide from fires. The nontoxic environments which might develop as a result of fire are difficult to predict.




Figure 8. Controlled temperature ventilation test equipment.



Table VI. Results of 24-Hour Controlled Temperature Ventilation Tests

1. Test	1	2	3	4
2. Cfm	1.3	3.5	3.5	3.5
3. Time of test (hr)	24	24	24	24
4. Max temp of air entering (F)	210	115	195	380
5. Max temp of air leaving (F)	70	70	85	105
6. Mean temp of air entering (F) <u>1/</u>	112	74	102.5	163.5
7. Mean temp of air leaving (F) <u>1/</u>	64.5	60	71.2	83.3
8. Total heat entering filter via air (Btu) <u>2/</u>	1750	1710	4320	9400
9. Total heat leaving filter via air (Btu) <u>3/</u>	153	460	1470	2120
10. Residual heat in sand after test (Btu) <u>4/</u>	195	-97	136	390
11. Heat lost through pipe wall (Btu) (item 8 minus items 9 and 10)	1402	1347	2714	6890
12. Capacity of soil A to absorb heat (Btu) <u>5/</u>	1375	501	1330	2860
13. Capacity of soil B to absorb heat (Btu) <u>5/</u>	4380	1580	4180	8980

1/ Mean temp equals datum temp plus the respective mean air temp rise. Datum temp was 55 F for tests 2 and 3 and 60 F for tests 1 and 4. Mean air temp rise in each case was computed from the area enclosed by the respective curve and datum line. Areas were measured with a planimeter.

2/ Based on mean temp rise of air entering.

3/ Based on mean temp rise of air leaving.

4/ Based on difference between sand temp at beginning and end of test.

5/ Based on a 3-ft length of 8-inch-diameter steel pipe. Soil temp assumed to be 55 F, and pipe temp assumed to be the average of items 6 and 7.




Figure 9. Test No. 1.




Figure 10. Test No. 2.




Figure 11. Test No. 3.




Figure 12. Test No. 4.




Figure 13. Sketch for a 300-cfm sand filter.




Figure 14. Sketch of heat sink for 300-cfm sand filter.

The estimated costs of material and construction for the filters shown in Figures 13 and 14 are \$4,000 and \$18,000, respectively.

It should also be mentioned that dry sand with its relatively low thermal conductivity effectively insulates the ventilation system against external heat when the system is not operating.

## CONCLUSIONS

1. Although the Artos sand filter will give significant blast protection against 1- and 10-megaton explosions, full knowledge of its capabilities would require further testing at longer durations.
2. Within the Artos specifications the effectiveness of the sand varies with changes in the size and distribution of the sand grains.
3. In low-pressure regions of medium time duration (25 psi at 2 seconds duration) Artos sand would be satisfactory, but in high-pressure regions of medium time duration (100 psi at 2 seconds duration) it would be necessary to use carefully graded sand.
4. The hot-blast tests gave good evidence that the sand can protect a shelter against the heat associated with overpressures up to 40 psi when the positive duration is two seconds or less, and can probably protect a shelter against a much stronger blast.
5. The controlled temperature ventilation tests showed that sand has excellent heat absorption capabilities. Calculations also indicate that a well-designed filter in certain types of soil would reject to the soil much of the absorbed heat.
6. The relatively high cost of a sand filter installation should be compared to the cost of other systems offering equal protection.

## REFERENCES

1. United States Atomic Energy Commission. The Effects of Nuclear Weapons, edited by Samuel Glasstone. Washington, April 1962, p 124.
2. United States Atomic Energy Commission. The Effects of Nuclear Weapons, edited by Samuel Glasstone. Washington, April 1962, p 557.



3. L. R. Ingersoll, et al. "Theory of Earth Heat Exchangers for the Heat Pump." ASHAE Transactions, Vol. 57 (1951), pp 171-172.

4. Beer, Ferdinand P., and E. Russel Johnston, Jr., Mechanics for Engineers. McGraw-Hill, New York, 1957. p 455.

#### ACKNOWLEDGMENTS

Appreciation is expressed to Mr. Donald S. Teague, Jr., of NCEL for his valuable advice concerning blast theory and model analysis. Appreciation is also expressed to Mr. Robert S. Chapler of NCEL for his contribution as chief technician.

Appendix A

**BLAST ATTENUATION TEST CURVES**




Figure A-1. Blast attenuation at different sand depths.




Figure A-2. Blast attenuation at different sand depths.




Figure A-3. Blast attenuation at different sand depths.




Figure A-4. Blast attenuation at different plenum volumes.




Figure A-5. Blast attenuation with enlarged plenum volume and filter diameter.




Figure A-6. Blast attenuation with different sand grain size and distribution.






Figure A-7. Blast attenuation with different sand grain size and distribution.

## Appendix B

### SAMPLE DATA AND CALCULATIONS

The steps in obtaining values to plot plenum pressure versus overpressure were as follows:

1. For each shot, the time duration of the blast wave is combined with overpressure to give impulse using the formula<sup>4</sup>

$$I = \frac{tP_o}{e} \quad (1)$$

where  $P_o$  = overpressure (psi)

$t$  = duration of the positive phase in seconds

$I$  = impulse (lb-sec/in.<sup>2</sup>)

$e = 2.718$

This formula is accurate at low overpressures but as overpressures are increased it gives impulse values which are higher than those of a nuclear blast.

2. The data for a typical series of shots is shown in Table B-I.

3. Values for plenum pressure are then plotted against impulse as shown in Figure B-1.

4. A linear regression is used to obtain the best straight line through the points. The equation for the line in Figure B-1 is

$$Y = 0.365 + 0.0362(X) \quad (2)$$

5. Values for plenum pressure and the corresponding impulse are then taken from this straight line. These quantities are listed in the first two columns of the following table.

Equation 1 with  $t = 2$  seconds is used to compute the corrected overpressures.

Impulse (lb-sec/in. 2)	Plenum Pressure (psi)	Overpressure (psi)
10	0.7	13.65
20	1.1	27.3
30	1.4	41
40	1.8	54.6
50	2.2	68.2
60	2.5	81.8
70	2.9	95.5
80	3.25	109.0

6. The above values of plenum pressure and overpressure are plotted as shown in Figure A-3.

The linear equations for the other tests in which plenum pressure is plotted against impulse are as follows:

Filter Diameter	Sand Depth	Plenum Volume	Equation
8	12	60	$Y = 1.17 + .08915(X)$
8	24	60	$Y = 0.59 + .0617(X)$
8	12	45	$Y = 0.92 + .1323(X)$
8	24	45	$Y = 0.47 + .0833(X)$
8	36	45	$Y = 0.25 + .049(X)$
8	12	30	$Y = 1.1 + .1445(X)$
8	24	30	$Y = 0.83 + .105(X)$
8	36	30	$Y = 0.41 + .073(X)$
12	24	105	$Y = 0.35 + .056(X)$
12	36	105	$Y = 0.58 + .070(X)$

Table B-1. Data for Typical Series of Blasts

Peak Over-pressure (psi)	Decay Time (sec)	Maximum Pressure in Plenum (psi)	Impulse (lb-sec/sq in.)	Initial Plenum Temp (F)	Max Plenum Temp (F)	Max Shock Tube Temp (F)	Min Shock Tube Temp (F)	Filter Exit Temp (F)	
								Before Shot	After Shot
105.5	1.72	2.8	66.76	70	79	152	50.5	66.5	66
100	1.82	2.8	66.96	70	80	145	42	66	66
106	2.49	3.8	97.10	71	85	152	35	66	65.5
79.5	1.79	2.1	52.35	71	80	136.5	47.5	66	65.5
79.5	1.79	2.3	52.35	71	80	155	9	65	65
75.5	1.77	2.1	49.16	71	80	131	32	65	64.5
60.6	1.63	1.5	36.34	72	78	120	52	64.5	64
60.6	1.73	1.9	38.77	72.5	79	148.5	26	64	64
61	2.19	2.5	49.15	73	81	157.5	37.5	64	63.5
40	1.93	1.4	28.40	73	78.5	104	44	63.5	63
41.8	2.07	1.5	31.83	—	—	120	50	64.5	64
43.8	2.10	1.6	33.84	—	—	118	38	64.5	64.0
24.6	2.13	1.0	19.28	—	—	100	50	64.5	63.5
27	2.42	1.2	24.04	—	—	98	44	64	63

Note: Sand depth 36 in.; plenum volume 60 cu ft.




Figure B-1. Plenum pressure versus impulse.

# DISTRIBUTION LIST

SNDL Code	No. of Activities	Total Copies	
	1	10	Chief, Bureau of Yards and Docks (Code 42)
23A	1	1	Naval Forces Commanders (Taiwan only)
39B	2	4	Construction Battalions
39D	10	10	Mobile Construction Battalions
39E	3	3	Amphibious Construction Battalions
39F	1	2	Construction Battalion Base Units
A2A	1	1	Chief of Naval Research - Only
A3	2	2	Chief of Naval Operation (OP-07, OP-04)
A5	5	5	Bureaus
B3	2	2	Colleges
E4	1	2	Laboratory ONR (Washington, D. C. only)
E5	1	1	Research Office ONR (Pasadena only)
E16	1	1	Training Device Center
F9	7	7	Station - CNO (Boston; Key West; San Juan; Long Beach; San Diego; Treasure Island; and Rodman, C. Z. only)
F17	6	6	Communication Station (San Juan; San Francisco; Pearl Harbor; Adak, Alaska; and Guam only)
F41	1	1	Security Station
F42	1	1	Radio Station (Oso and Cheltenham only)
F48	1	1	Security Group Activities (Winter Harbor only)
H3	8	8	Hospital (Chelsea; St. Albans, Portsmouth, Va; Beaufort; Great Lakes; San Diego; Oakland; and Camp Pendleton only)
H6	1	1	Medical Center
J1	2	2	Administration Command and Unit - BuPers (Great Lakes and San Diego only)
J3	1	1	U. S. Fleet Anti-Air Warfare Training Center (Virginia Beach only)
J4	2	2	Amphibious Bases
J19	1	1	Receiving Station (Brooklyn only)
J34	1	1	Station - BuPers (Washington, D. C. only)
J46	1	1	Personnel Center
J48	1	1	Construction Training Unit
J60	1	1	School Academy
J65	1	1	School CEC Officers
J84	1	1	School Postgraduate
J90	1	1	School Supply Corps

# DISTRIBUTION LIST (Cont'd)

SNDL Code	No. of Activities	Total Copies	
J95	1	1	School War College
J99	1	1	Communication Training Center
L1	11	11	Shipyards
L7	4	4	Laboratory - BuShips (New London; Panama City; Carderock; and Annapolis only)
L26	5	5	Naval Facilities - BuShips (Antigua; Turks Island; Barbados; San Salvador; and Eleuthera only)
L30	1	1	Submarine Base (Groton, Conn. only)
L32	2	2	Naval Support Activities (London and Naples only)
L42	2	2	Fleet Activities - BuShips
M27	4	4	Supply Center
M28	6	6	Supply Depot (except Guantanamo Bay; Subic Bay; and Yokosuka)
M61	2	2	Aviation Supply Office
N1	6	18	BuDocks Director, Overseas Division
N2	9	27	Public Works Offices
N5	3	9	Construction Battalion Center
N6	5	5	Construction Officer-in-Charge
N7	1	1	Construction Resident-Officer-in-Charge
N9	6	12	Public Works Center
N14	1	1	Housing Activity
R9	2	2	Recruit Depots
R10	2	2	Supply Installations (Albany and Barstow only)
R20	1	1	Marine Corps Schools (Quantico)
R64	3	3	Marine Corps Base
R66	1	1	Marine Corps Camp Detachment (Tengan only)
W1A1	6	6	Air Station
W1A2	35	35	Air Station
W1B	8	8	Air Station Auxiliary
W1C	4	4	Air Facility (Phoenix; Monterey; Oppama; Naha; and Naples only)
W1E	6	6	Marine Corps Air Station (except Quantico)
W1H	9	9	Station - BuWeps (except Rota)
	1	1	Deputy Chief of Staff, Research and Development, Headquarters, U. S. Marine Corps, Washington, D. C.
	1	1	President, Marine Corps Equipment Board, Marine Corps School, Quantico, Va.
	1	2	Library of Congress, Washington, D. C.
	1	1	Headquarters, U. S. Army Chemical Corps, Engineering Command, Chemical Center, Md.

# DISTRIBUTION LIST (Cont'd)

No. of Activities	Total Copies	
1	1	Chief of Staff, U. S. Army, Chief of Research and Development, Department of the Army, Washington, D. C.
1	1	Office of the Chief of Engineers, Assistant Chief of Engineering for Civil Works, Department of the Army, Washington, D. C.
1	1	Chief of Engineers, Department of the Army, Washington, D. C., Attn: Engineering Research and Development Division
1	1	Chief of Engineers, Department of the Army, Washington, D. C., Attn: ENGCW-OE
1	1	Director, U. S. Army Engineer Research and Development Laboratories, Fort Belvoir, Va., Attn: Information Resources Branch
1	1	ASD (ASNRR), Wright-Patterson Air Force Base, Ohio
1	3	Headquarters, U. S. Air Force, Directorate of Civil Engineering, Washington, D. C., Attn: AFOCE-ES
1	1	Commanding Officer, U. S. Naval Construction Battalion Center, Port Hueneme, Calif., Attn: Materiel Dept., Code 140
1	1	Deputy Chief of Staff, Development, Director of Research and Development, Department of the Air Force, Washington, D. C.
1	1	Director, National Bureau of Standards, Department of Commerce, Connecticut Avenue, Washington, D. C.
1	2	Office of the Director, U. S. Coast and Geodetic Survey, Washington, D. C.
1	20	Defense Documentation Center, Building 5, Cameron Station, Alexandria, Va.
1	2	Director of Defense Research and Engineering, Department of Defense, Washington, D. C.
1	2	Director, Division of Plans and Policies, Headquarters, U. S. Marine Corps, Washington, D. C.
1	2	Director, Bureau of Reclamation, Washington, D. C.
1	1	Facilities Officer, Code 108, Office of Naval Research, Washington, D. C.
1	1	Federal Aviation Agency, Office of Management Services, Administrative Services Division, Washington, D. C., Attn: Library Branch
1	2	Commander Naval Beach Group TWO, U. S. Naval Amphibious Base, Little Creek, Norfolk, Va.
1	1	Director, U. S. Naval Ordnance Laboratory, White Oak, Silver Springs, Md.
1	1	Office of Naval Research, Branch Office, Navy No. 100, Box 39, FPO, New York
1	1	U. S. Naval Radiological Defense Laboratory, San Francisco
1	1	Officer in Charge, CECOS, Port Hueneme, Calif., Attn: ADCE Course
1	1	U. S. Air Force, Asst. Chief of Staff, Intelligence, Building B, AHS, Washington, D. C., Attn: Mr. Sargent White
1	1	Commander, Air Force Ballistic Missile Division, Air Research and Development Command, P. O. Box 262, Inglewood, Calif.
1	1	Directorate of Research, Air Force Weapons Laboratory, Kirtland Air Force Base, N. M.
1	1	Office of the Chief of Engineers, Department of the Army, T-7, Gravelly Point, Washington, D. C., Attn: ENGNB
1	1	Commanding Officer, Engineer Research and Development Laboratories, Fort Belvoir, Va.
1	1	Commander, Pacific Missile Range, Technical Documentation Section, P. O. Box 10, Point Mugu, Calif., Attn: Code 4332



# DISTRIBUTION LIST (Cont'd)

No. of Activities	Total Copies	
1	1	Office of the Chief of Engineers, Department of the Army, T-7, Gravelly Point, Washington, D. C., Attn: ENG MC-EB
1	1	Director, U. S. Army Engineer Waterways Experiment Station, P. O. Box 631, Vicksburg, Miss., Attn: Mr. G. L. Arbuthnot, Jr.
1	1	U. S. Army Chemical Center, Nuclear Defense Laboratory, Edgewood, Md.
1	1	Director, Ballistic Research Laboratories, Aberdeen, Md.
1	2	Chief, Defense Atomic Support Agency, Washington, D. C.
1	1	Headquarters, Field Command, Defense Atomic Support Agency, Sandia Base, Albuquerque, N. M.
1	1	U. S. Atomic Energy Commission, Technical Information Service, P. O. Box 62, Oak Ridge, Tenn.
1	1	Director, Civil Effects Test Group, Atomic Energy Commission, Washington, D. C.
1	1	Formulation and Analysis Branch, Mathematics and Computation Laboratory, National Resource Evaluation Center, Office of Emergency Planning, Washington, D. C.
1	1	Officer in Charge, U. S. Naval Supply Research and Development Facility, Naval Supply Center, Bayonne, N. J.
1	1	Commander, U. S. Naval Shipyard, Boston, Mass. Attn: Materials and Chemical Laboratory
1	1	Commander, U. S. Naval Shipyard, Brooklyn, N. Y., Attn: Material Laboratory
1	1	Commanding Officer, Field Research Laboratory, Bureau of Medicine and Surgery, Camp Lejeune, N. C.
1	4	U. S. Army Material Command, Washington, D. C.
1	1	Directorate of Medical Research, Chemical Warfare Laboratory, Army Chemical Center, Md.
1	1	U. S. Army Corps of Engineers, Office of the District Engineer, St. Paul District, 1217 U. S. P. O. and Customs House, St. Paul, Minn.
1	1	U. S. Army Cold Regions Research and Engineering Laboratory, Corps of Engineers, P. O. Box 282, Hanover, N. H.
1	1	Chief, Concrete Division, Waterways Experiment Station, P. O. Drawer 2131, Jackson, Miss.
1	1	Air Force Cambridge Research Center, Hanscom Field, Bedford, Mass.
1	1	Commanding Officer, Biological Warfare Laboratories, Fort Detrick, Frederick, Md.
1	1	Chief, Physical Research Branch, Research Division, U. S. Department of Commerce, Bureau of Public Roads, Washington, D. C.
1	1	Director, Soil Physics Laboratory, Department of Engineering, Princeton University, Princeton, N. J., Attn: Library
1	1	Mr. William J. Taylor, Terminal Ballistics Laboratory, Aberdeen Proving Ground, Md.
1	1	LCDR Charles W. Gulick, Jr., CEC, USN, Navy No. 926, FPO, San Francisco
1	1	LCDR J. C. LeDoux, Office of Civil Defense, Department of Defense, Washington, D. C.
1	1	CAPT W. M. McLellan, CEC, USN, Office of Civil Defense Support, Building T-7, Washington, D. C.
1	1	LT Edward S. Perry, U. S. Naval Reserve Officers Training Corps Unit, University of Illinois, Urbana, Ill.

# DISTRIBUTION LIST (Cont'd)

No. of Activities	Total Copies	
1	1	LCDR N. W. Clements, CEC, USN, Navy Nuclear Power Unit, Fort Belvoir, Va.
1	1	CDR C. Curione, CEC, USN, U. S. Naval Civil Engineering Laboratory, Port Hueneme, Calif.
1	1	LTJG L. K. Donovan, CEC, USN, Navy Nuclear Power Unit, Fort Belvoir, Va.
1	1	LT Walter J. Eager, Jr., CEC, USN, Naval Postgraduate School, Monterey, Calif.
1	1	LTJG Clinton W. Kelly, III, CEC, USN, Bureau of Yards and Docks, Program Officer, U. S. Naval Radiological Defense Laboratory, San Francisco
1	1	CDR W. J. Francy, CEC, USN, Bureau of Yards and Docks, Director, Southeast Division, U. S. Naval Base, Charleston, S. C.
1	1	CDR C. F. Krickenberg, CEC, USN, Bureau of Yards and Docks, Code 50.200, Washington, D. C.
1	1	Dr. Lauriston S. Taylor, Chief, Radiation Physics Division, National Bureau of Standards, Washington, D. C.
1	1	Dr. James O. Buchanan, Technical Operations, Inc., South Avenue, Burlington, Mass.
1	1	LT S. H. Mathes, CEC, USN, U. S. Naval Construction Battalion Center, Port Hueneme, Calif.
1	1	Mr. Jack C. Greene, Office of Civil Defense, Department of Defense, Washington, D. C.
1	1	Dr. Harold A. Knapp, Fallout Studies Branch, Division of Biology and Medicine, U. S. Atomic Energy Commission, Washington, D. C.
1	1	Dr. Karl Z. Morgan, Director, Health Physics Division, Oak Ridge National Laboratory, Oak Ridge, Tenn.
1	1	Dr. Joseph D. Coker, National Resource Evaluation Center, Executive Office Building, Washington, D. C.
1	1	Dr. Charles F. Ksanda, Military Evaluation Division, U. S. Naval Radiological Defense Laboratory, San Francisco
1	1	Dr. George E. Pugh, Institute of Defense Analyses, Weapons Systems Evaluation Division, Washington, D. C.
1	1	Mr. John Auxier, Oak Ridge National Laboratory, Oak Ridge, Tenn.
1	1	Dr. William Kreger, Naval Radiological Defense Laboratory, San Francisco
1	1	Dr. Hans Tiller, Nuclear Defense Laboratory, Army Chemical Center, Md.
1	1	Mr. Irving Gaskill, National Resource Evaluation Center, Executive Office Building, Washington, D. C.
1	1	Major Robert S. Marcum, Defense Atomic Support Agency, Department of Defense, Washington, D. C.
1	1	Dr. Carl F. Miller, Office of Civil Defense, Department of Defense, Washington, D. C.
1	1	Mr. James C. Pettee, National Resource Evaluation Center, Executive Office Building, Washington, D. C.
1	1	LTCOL Russell J. Hutchinson, 052921, Office of the Engineer, Camp Walters, Mineral Wells, Tex.
1	1	LCDR I. D. Crowley, CEC, USN, U. S. Naval School, CEC Officers, Port Hueneme, Calif.
1	1	LTCOL James R. Bohanan, USAF, Headquarters, Directorate of Civil Engineering, Washington, D. C.

# DISTRIBUTION LIST (Cont'd)

No. of Activities	Total Copies	
1	1	Mr. Kenneth Kaplan, Broadview Research Corporation, 1811 Trousdale Drive, Burlingame, Calif.
1	1	Mr. Thomas Morrison, American Machine and Foundry Company, 7501 North Natchez Avenue, Niles, Ill.
1	1	Mr. Walter Gunther, The Mitre Corporation, P. O. Box 208, Lexington, Mass.
1	1	Mr. W. R. Perret - 5112, Applied Experiments Division, Sandia Corporation, Albuquerque, N. M.
1	1	Mr. Lyndon Welch, Eberle M. Smith Associates, Inc., 153 East Elizabeth Street, Detroit, Mich.
1	1	Professor Herbert M. Bosch, Public Health Engineering, School of Public Health, University of Minnesota, Minneapolis, Minn.
1	1	Dr. Merit P. White, Civil Engineering Department, School of Engineering, University of Massachusetts, Amherst, Mass.
1	1	Dr. Robert J. Hansen, Department of Civil & Sanitary Engineering, Massachusetts Institute of Technology, Cambridge, Mass.
1	1	Mr. Harold Horowitz, Building Research Institute, National Academy of Sciences, 2101 Constitution Avenue, N. W., Washington, D. C.
1	1	Mr. Luke Vortman - 5112, Applied Experiments Division, Sandia Corporation, Albuquerque, N. M.
1	1	Mr. Richard Park, National Academy of Sciences, 2101 Constitution Avenue, N. W., Washington, D. C.
1	1	Mr. Frederick A. Pawley, AIA Research Secretary, American Institute of Architects, 1735 New York Avenue, N. W., Washington, D. C.
1	1	Dr. David Kleinecke, Engineering Field Station, University of California, 1301 South 46th Street, Richmond, Calif.
1	1	Dr. E. E. Massey, Defense Research Board, Department of National Defense, Ottawa, Canada
1	1	Dr. Robert Rapp, The Rand Corporation, 1700 Main Street, Santa Monica, Calif.
1	1	Dr. Stephen B. Withey, Program Director, Survey Research Center, University of Michigan, Ann Arbor, Mich.
1	1	Dr. Eric T. Clarke, Technical Operations, Inc., Burlington, Mass.
1	1	Dr. A. B. Chilton, Civil Engineering Hall, University of Illinois, Urbana, Ill.
1	1	Mrs. Shea Valley, CRTZS, A. F. Cambridge Research Center, Bedford, Mass.
1	1	Professor J. T. Hanley, Department of Civil Engineering, University of Minnesota, Minneapolis, Minn.
1	1	Asst. Professor J. Silverman, Department of Chemical Engineering, University of Maryland, College Park, Md.
1	1	Dr. F. T. Mavis, Dean, College of Engineering, University of Maryland, College Park, Md.
1	1	Dr. Raymond R. Fox, Associate Professor and Director, Protective Construction Courses, The George Washington University, Washington, D. C.

# DISTRIBUTION LIST (Cont'd)

No. of Activities	Total Copies	
1	1	CDR H. L. Murphy, Room 211, Federal Office Building, San Francisco
1	1	LCDR W. H. Bannister, CEC, USN, Field Command, Defense Atomic Support Agency, Sandia Base, Albuquerque, N. M.
1	1	Major Robert Crawford, USAF, Air Force Weapons Laboratory, Kirtland Air Force Base, Albuquerque, N. M.
1	1	Dr. John Balloch, Director, Operations Analysis, 26th Air Division, SAGE, Hancock Field, Syracuse, N. Y.
1	1	Mr. J. F. Tamanini, A & E Development Division, Office of Civil Defense, Department of Defense, Washington, D. C.
1	1	LCDR C. R. Whipple, CEC, USN, U. S. Naval Ordnance Laboratory, White Oak, Md.
1	1	Dr. W. E. Fisher, Air Force Weapons Laboratory, Kirtland Air Force Base, Albuquerque, N. M.
1	1	Mr. Everitt P. Blizard, Director, Neutron Physics, Oak Ridge National Laboratory, P. O. Box X, Oak Ridge, Tenn.
1	1	LCDR T. Yoshihara, CEC, USN, U. S. Naval Civil Engineering Laboratory, Port Hueneme, Calif.
1	1	LT M. MacDonald, CEC, USN, U. S. Naval School, CEC Officers, Port Hueneme, Calif.
1	1	Library, Engineering Department, University of California, 405 Hilgard Avenue, Los Angeles
1	1	Sandia Corporation, Box 5800, Albuquerque, N. M.
1	1	Rivers and Harbor Library, Princeton University, Princeton, N. J.
1	1	Head, Civil Engineering Department, Carnegie Institute of Technology, Schenley Park, Pittsburgh, Pa.
1	1	Mr. G. H. Albright, Pennsylvania State University, College of Engineering and Architecture, University Park, Pa.
1	1	Mr. A. F. Dill, Civil Engineering Hall, University of Illinois, Urbana, Ill.
1	1	Dr. N. M. Newmark, Civil Engineering Hall, University of Illinois, Urbana, Ill.
1	1	Professor J. Neils Thompson, Civil Engineering Department, University of Texas, Austin, Tex.
1	1	Mr. Fred Sauer, Physics Department, Stanford Research Institute, Menlo Park, Calif.
1	1	Dr. T. H. Schiffman, Armour Research Foundation of Illinois, Institute of Technology, Technology Center, Chicago, Ill.
1	1	Dr. Robert V. Whitman, Massachusetts Institute of Technology, Cambridge, Mass.
1	1	Dr. Lewis V. Spencer, Ottawa University, Physics Department, Ottawa, Kan.
1	1	Mr. E. E. Shalowitz, Protective Construction, GSA Building, 19th and F Streets, N. W., Washington, D. C.
1	1	Mr. Werner Weber, Nuclear Engineering Consultant, N. Y. State Civil Defense Commission, P. O. Box 7007, State Office Building, Albany, N. Y.
1	1	Dr. Harold Brode, The Rand Corporation, 1700 Main Street, Santa Monica, Calif.
1	1	Mr. R. D. Cavanaugh, Barry Controls, Inc., 700 Pleasant Street, Watertown, Mass.

## DISTRIBUTION LIST (Cont'd)

No. of Activities	Total Copies	
1	1	CAPT L. N. Saunders, CEC, USN, Code C10, U. S. Naval Construction Battalion Center, Port Hueneme, Calif.
1	1	CDR E. M. Saunders, CEC, USN, Bureau of Yards and Docks, Code 42.330, Washington, D. C.
1	1	CDR H. E. Stephens, CEC, USN, Bureau of Yards and Docks, Code 41.101, Washington, D. C.
1	1	LCDR R. C. Vance, Executive Officer, Mobile Construction Battalion 11, FPO, San Francisco
1	1	LCDR W. A. Walls, CEC, USN, Defense Atomic Support Agency, Washington, D. C.
1	1	Major F. A. Verser, Jr., USA, Defense Atomic Support Agency, Washington, D. C.
1	1	Mr. L. Neal FitzSimons, Office of Civil Defense, Department of Defense, Washington, D. C.
1	1	Mr. Ben Taylor, Office of Civil Defense, Department of Defense, Washington, D. C.
1	1	Mr. Charles M. Eisenhower, Radiation Physics Laboratory, National Bureau of Standards, Washington, D. C.
1	1	Mr. O. H. Hill, Building 12, Room 505, Radiation Physics Division, National Bureau of Standards, Washington, D. C.
1	1	LCDR J. D. Andrews, CEC, USN, SHAPE Headquarters, APO 55, New York
1	1	CDR W. J. Christensen, CEC, USN, U. S. Naval Civil Engineering Laboratory, Port Hueneme, Calif.

No. of  
Activities

Total  
Copies

- I. Sand filter — Shelter ventilation
- I. Stephenson, J. M.
- II. Y-F011-05-338b

U. S. Naval Civil Engineering Laboratory  
Technical Report R-263  
TEST OF GERMAN SAND-TYPE FILTER, by  
J. M. Stephenson 11 Nov 63 UNCLASSIFIED  
48 p. illus  
Tests of a German sand filter to determine its effective attenuation and heat absorption in nuclear blast.

- I. Sand filter — Shelter ventilation
- I. Stephenson, J. M.
- II. Y-F011-05-338b

U. S. Naval Civil Engineering Laboratory  
Technical Report R-263  
TEST OF GERMAN SAND-TYPE FILTER, by  
J. M. Stephenson 11 Nov 63 UNCLASSIFIED  
48 p. illus  
Tests of a German sand filter to determine its effective attenuation and heat absorption in nuclear blast.

- I. Sand filter — Shelter ventilation
- I. Stephenson, J. M.
- II. Y-F011-05-338b

U. S. Naval Civil Engineering Laboratory  
Technical Report R-263  
TEST OF GERMAN SAND-TYPE FILTER, by  
J. M. Stephenson 11 Nov 63 UNCLASSIFIED  
48 p. illus  
Tests of a German sand filter to determine its effective attenuation and heat absorption in nuclear blast.

- I. Sand filter — Shelter ventilation
- I. Stephenson, J. M.
- II. Y-F011-05-338b

U. S. Naval Civil Engineering Laboratory  
Technical Report R-263  
TEST OF GERMAN SAND-TYPE FILTER, by  
J. M. Stephenson 11 Nov 63 UNCLASSIFIED  
48 p. illus  
Tests of a German sand filter to determine its effective attenuation and heat absorption in nuclear blast.